



**ADDENDUM NUMBER 1**

**INVITATION TO BID #18-055  
FY 2018 Deep Mill Patching Project  
for  
the City of Sandy Springs**

**PROPOSALS DUE:  
March 29, 2018 NO LATER THAN 2:00 P.M., EST**

**COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB.**

---

**To All Prospective Offerors:**

In reference to the ITB listed above, the following answers to questions, additions, deletions and changes are hereby incorporated into the Invitation to Bid:

**Questions:**

1) In Article 2 Section 2.4 it states the working hours are from 8AM to 5PM Monday - Friday but in the General Notes Number 11. it states the working hours are from 9AM to 3PM. Will the City please clarify the working hours? **Work hours will be from 9AM to 3PM Monday – Friday.**

2) Will the City provide the size and quantity of the traffic loops that will need to be replaced? **No traffic loops are affected with this project.**

3) Will the contractor be able to put down 5" of 12.5MM in the appropriate lifts in lieu of 3" of 19MM and 2" of 12.5MM? **This would be more cost effective for the City then running two different types of mixes for such small quantities. Yes, 5" of 12.5MM in the appropriate lifts in lieu of 3" of 19MM and 2" of 12.5MM will be acceptable.**

I hereby acknowledge receipt of Addendum Number 1 for #18-055 FY 2018 Deep Mill Patching project and have incorporated the changes into my response for the abovementioned Invitation to Bid.

COMPANY NAME: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY: \_\_\_\_\_ STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_ EMAIL ADDRESS: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

