

Private Hydrant/Water Main Report

Inspector Name: _____ Registration #: _____

Name of Community: _____

Address of Community: _____

Date of Inspection/Maintenance: _____

Item#	Minimum Standards	Pass	Fail	Action Required For Compliance
1	Hydrants Inspected annually & after each operation (NFPA 25, 7.2.2.5)			
2	Mainline strainers maintenance annually & after each operation(NFPA 25, 7.4.2)			
3	Piping (exposed & underground) flow test every 5 years (NFPA 25, 7.3.1)			
4	Hydrants shall be accessible for use by fire department (NFPA 25, 7.2.2.5)			
5	No leaks in outlets or at top of hydrant (NFPA 25, 7.2.2.5)			
6	No cracks in hydrant barrel (NFPA 25, 7.2.2.5)			
7	Hydrant outlets tight (NFPA 25, 7.2.2.5)			
8	Hydrant nozzle threads not worn (NFPA 25, 7.2.2.5)			
9	Hydrant operating nut not worn (NFPA 25, 7.2.2.5)			
10	Each hydrant opened fully and water flowed until all foreign material has cleared (NFPA 25, 7.3.2.1)			
11	Each hydrant flow shall be maintained for 1 minute (NFPA 25, 7.3.2.2)			
12	Full drainage of each hydrant shall take no longer than 60 minutes (NFPA 25, 7.3.2.4)			
13	Hydrants shall be lubricated annually to ensure all stems, caps, plugs, and threads are in proper operating condition. (NFPA 25, 7.4.3.1)			
14	Hydrants painted silver with orange reflective tape around bonnet			

Signature of Inspector

ATTACH FLOW REPORTS
